

Memo

Project: National Paediatric Hospital

Report Type: Summary of Noise Vibration & Movement Monitoring Results

Period of Monitoring: 2nd September – 14th October 2019

Introduction

Contained within the project documents for the National Children’s Hospital development are requirements for Environmental Monitoring to be completed during construction works. This monitoring regime includes recording dust deposition, noise at the perimeter of the site, and ground vibration at the perimeter of the site. Permissible limits for each monitoring regime have been set out in the Project EIS which was submitted with the Planning Permission for the Hospital.

The number of Monitoring points will vary throughout the project depending on the construction works being undertaken. Additional monitoring points may be added if particular features of adjacent properties require it.

Works on site during this monitoring period include, but are not limited to:

- Steel, electrical and excavation work and road compaction at O’Reilly Avenue/Energy Centre.
- Concrete pouring, steel works and excavation of materials at the hospital entrance.
- Pouring concrete and steel works near Cameron Square.
- Construction of ground & upper level and excavation works near South Circular Road.
- Pouring concrete and steel works near Mount Brown.
- Excavation, steel works, pouring concrete and depositing material near Brookfield Clinic.

Vibration Monitoring.

Vibration monitors have been located at the ‘closest part of sensitive property’ as per the Project Environmental Impact Statement where feasible or alternatively at the site hoarding. The monitors will be located as per the above adjacent to locations where significant works are ongoing on site.

The Project Environmental Impact Statement (EIS) that was part of the project Planning Permission established vibration limit at structures depending on their condition and type. Please see tables below for the limits set.

Table 11.7: Allowable vibration during construction phase for soundly constructed buildings

Allowable vibration (in terms of peak particle velocity) at the closest part of sensitive property to the source of vibration, at a frequency of		
Less than 10Hz	10 to 50Hz	50 to 100Hz (and above)
15 mm/s	20 mm/s	50 mm/s

Memo

Table 11.8: Allowable vibration during construction phase for sensitive buildings

Allowable vibration (in terms of peak particle velocity) at the closest part of sensitive property to the source of vibration, at a frequency of		
Less than 10Hz	10 to 50Hz	50 to 100Hz (and above)
3 mm/s	3 – 8 mm/s	8 – 10 mm/s

Site operations are monitored using a traffic light trigger system of Green, Amber and Red trigger levels with the Red trigger level set at a vibration limit of 3mm/s PPV which corresponds to the lowest permissible vibration limit for sensitive structures. Any vibration level recorded below Red levels is acceptable within the limits established in Planning.

Number of Monitors on Site:

During the monitoring period summarised for this report (2nd September – 14th October 2019) there were up to 16 active vibration monitors installed at the perimeter of the site.

Location of Vibration and Noise Monitors:

The layout of the monitors is as seen below:



Location of Vibration Monitors

There are concentrations of monitors at the boundaries with Cameron Square and O'Reilly Avenue where works have been ongoing on site in proximity to neighbouring properties.

Memo



Location of Noise Monitors near O'Reilly Avenue

Observations:

Executive Summary:

Vibration monitors have been placed at the 'closest part of the sensitive properties' as per the EIS where this is feasible. The majority of vibration readings during the monitoring period recorded readings below the limit specified within the Project EIS. Vibration monitors V1, V13, V18, A1 & A2 have been excluded from this report as they are not relevant to the conditions for the residents adjacent to the site. From the remaining 11 monitors:

- 2 monitors recorded readings above the limit specified within the Project EIS.
- 1 monitor was offline during the timeframe covered in this report.

Detailed Summary:

Sensor (V2 – 3835) (James' Walk)

- All vibration readings recorded vibrations below the limit specified within the Project EIS.
- Monitor was offline from 9th October 2019 continuously until the end of the timeframe covered in this report.

Sensor (V3 – 8995) (South Circular Road) (previously numbered 8838)

- All vibration readings recorded vibrations below the limit specified within the Project EIS.

Sensor (V5 – 5037) (Cameron Square) (previously numbered 9155)

- All vibration readings recorded vibrations below the limit specified within the Project EIS.

Sensor (V6 - 5044) (Cameron Square)) (previously numbered 9736)

- All vibration readings recorded vibrations below the limit specified within the Project EIS.

Sensor (V7 - 5017) (Old Kilmainham Road) (previously numbered 9734)

All vibration readings recorded vibrations below the limit specified within the Project EIS.

Memo

Sensor (V8 - 5035) (Brookfield Clinic) (previously numbered 3485)

- All vibration readings recorded vibrations below the limit specified within the Project EIS.

Sensor (V9 – 5050) (O’Reilly Avenue) (previously numbered 8995)

- All vibration readings recorded vibrations below the limit specified within the Project EIS.

Sensor (V10 – 4183) (O’Reilly Avenue)

- Vibrations above the limit specified within the Project EIS were recorded on the following dates: 21st September 2019.
- The vibration report states the cause of these vibrations was “*unknown source*” but the breach occurred on a Saturday.

Sensor (V11 – 8988) (O’Reilly Avenue) (previously numbered 8893)

- Vibrations above the limit specified within the Project EIS were recorded on the following dates: 3rd & 4th October 2019.
- The vibration report states the cause of these vibrations was: “*a small digger cleaning the vegetation in the back garden*”.

Sensor (V12 – 5043) (O’Reilly Avenue) (previously numbered 3252)

- All vibration readings recorded vibrations below the limit specified within the Project EIS.

Sensor (V14 - 5056) (Mount Shannon) (previously numbered 9737)

- All vibration readings recorded vibrations below the limit specified within the Project EIS.

Memo

Noise Monitoring.

During the report period noise monitors have been placed at the 'closest part of sensitive property' as per the Project EIS where this has been feasible, or alternatively to the outside face of the site hoarding. When works are ongoing the noise monitor sensors run continuously, and readings are recorded in decibels (dB) LA_{eq1hr}. Decibels is the standard unit of measurement of sound energy and 'LA_{eq1hr}' means that sensors record all levels of sound over a 1 hour period and then calculate an average equivalent decibel level as if the sound was continuous. Isolated instantaneous loud noises are thus averaged out.

The Project Environmental Impact Statement (EIS) that was part of the project Planning Permission established a noise limit at residential dwellings of 70dB LA_{eq1hr}. Site operations are monitored using a traffic light trigger system of Green, Amber and Red trigger levels with the Red trigger level set at the noise limit set out in the project EIS (70 dB LA_{eq1hr}). Any noise level recorded below Red levels is acceptable within the limits established in Planning.

Number of Noise Monitors on Site:

During the monitoring period (2nd September – 14th October 2019) summarised for this report there were up to 16 active monitors at the site boundaries.

Observations:

Executive Summary:

Noise monitors 07, 08, 15 & 16 have been excluded from this report as they are not relevant to the conditions for the residents adjacent to the site. From the remaining 12 monitors:

- 8 number monitors recorded readings above the limit specified within the Project EIS.
- 3 monitor recorded readings above the DCC daily 10 hour limit.
- 2 monitor was offline during the timeframe covered in this report.

Detailed Summary:

The monitoring results for noise for this period were within the limits set out in the Project EIS with the following exceptions:

Monitor 01 (Cameron Square)

- All noise readings recorded noise levels below the limit specified within the Project EIS.

Monitor 02 (O'Reilly Avenue)

- All noise readings recorded noise levels below the limit specified within the Project EIS.

Monitor 03 (Mace)

- Noise levels above the limit specified within the Project EIS were recorded on the following dates: 2nd, 4th, 13th, 17th, 18th, 25th, 27th, 28th & 30th September 2019 and 1st, 2nd, 3rd, 4th, 5th, 7th, 8th, 9th, 10th, 11th & 12th October 2019.
- The noise report states the cause of these readings was: "*ambient traffic noise.*"

Memo

Monitor 04 (Mount Brown Road)

- Noise levels above the limit specified within the Project EIS were recorded on the following dates: 2nd, 3rd, 4th, 5th, 6th, 7th, 8th, 9th, 10th, 11th, 12th, 13th, 14th, 15th, 16th, 17th, 18th, 19th, 20th, 21st, 22nd, 23rd, 24th, 25th, 26th, 27th, 28th, 29th, 30th September 2019 and 1st, 2nd, 3rd, 4th, 5th, 6th, 7th, 8th, 9th, 10th, 11th, 12th & 13th October 2019.
- The noise report states the cause of these readings was: “*ambient noise*.”
- Noise levels in excess of the 75dB DCC daily 10 hour limit were recorded on the following dates:
 - 12th September 2019, the noise report states the cause of this breach was “*ambient traffic noise from concrete trucks*”. The value of the exceedance is 75.4 dB LA_{eq10hr}.
 - 23rd September 2019, the noise report states the cause of this breach was “*ambient traffic noise*”. The value of the exceedance is 75.8 dB LA_{eq10hr}.
 - 24th September 2019, the noise report states the cause of this breach was “*ambient traffic noise*”. The value of the exceedance is 76 dB LA_{eq10hr}.
 - 25th September 2019, the noise report states the cause of this breach was “*ambient traffic noise*”. The value of the exceedance is 75.3 dB LA_{eq10hr}.
 - 30th September 2019, the noise report states the cause of this breach was “*ambient traffic noise*”. The value of the exceedance is 75.7 dB LA_{eq10hr}.
 - 1st October 2019, the noise report states the cause of this breach was “*ambient traffic noise*”. The value of the exceedance is 75.9 dB LA_{eq10hr}.
 - 2nd October 2019, the noise report states the cause of this breach was “*ambient traffic noise*” & “*an anchor drill*”. The value of the exceedance is 77.1 dB LA_{eq10hr}.
 - 4th October 2019, the noise report states the cause of this breach was “*ambient traffic noise*”. The value of the exceedance is 77.6 dB LA_{eq10hr}.

Monitor 05 (O'Reilly Avenue)

- Noise levels above the limit specified within the Project EIS were recorded on the following dates: 3rd & 10th October 2019.
- No reason was given for the exceedances in the noise report.

Monitor 06 (O'Reilly Avenue)

- Noise levels above the limit specified within the Project EIS were recorded on the following dates: 18th & 19th September 2019 and 4th October 2019.
- The noise report states the cause of these readings was: “*excavation works*”.

Monitor 09 (James' Walk)

- Noise levels above the limit specified within the Project EIS were recorded on the following dates: 2nd, 3rd, 18th, 19th, 23rd, 25th, 26th, 27th & 28th September 2019 and 2nd, 3rd, 4th, 6th, 7th & 8th October 2019.
- The noise report states the cause of these readings was: “*works being completed in the resident's garden*.”
- The monitor was offline for less than a day on: 6th & 7th October 2019. Monitor was offline from 9th October 2019 continuously until the end of the timeframe covered in this report.
- Noise levels in excess of the 75dB DCC daily 10 hour limit were recorded on the following dates:

Memo

- 19th September 2019, the noise report states the cause of this breach was “*works being completed in the resident's garden*”. The value of the exceedance is 76.5 dB LA_{eq10hr}.
- 25th September 2019, the noise report states the cause of this breach was “*works being completed in the resident's garden*”. The value of the exceedance is 76.2 dB LA_{eq10hr}.
- 27th September 2019, the noise report states the cause of this breach was “*works being completed in the resident's garden*”. The value of the exceedance is 75.2 dB LA_{eq10hr}.

Monitor 10 (Brookfield Clinic)

- Noise levels above the limit specified within the Project EIS were recorded on the following dates: 4th, 6th, 19th, 20th, 27th & 30th September 2019 and 2nd, 3rd, 7th & 11th October.
- The noise report states the causes of these readings were down to an “*unknown source*” and on 4th September 2019 the exceedance is stated to be caused by the “*breaking out of concrete*”.

Monitor 11 (Cameron Square)

- All noise readings recorded noise levels below the limit specified within the Project EIS.

Monitor 12 (Cameron Square)

- Noise levels above the limit specified within the Project EIS were recorded on the following dates: 10th September 2019.
- No reason was given for the exceedances in the noise report.
- All noise readings recorded noise levels below the limit specified within the Project EIS.

Monitor 14 (Mount Shannon Road)

- Noise levels above the limit specified within the Project EIS were recorded on the following dates: 2nd, 3rd, 4th, 5th, 6th, 7th, 9th, 10th, 11th, 12th, 13th, 14th, 15th, 16th, 17th, 18th, 19th, 20th, 22nd, 23rd, 24th, 25th, 26th, 27th, 28th, 30th September 2019 and 1st, 2nd, 3rd, 4th, 5th, 7th, 8th, 9th, 10th, 11th, 12th & 13th October 2019.
- The monitor was offline for less than a day on: 10th & 11th October 2019.
- The noise report states the cause of these readings was: “*ambient noise*.”
- Noise levels in excess of the 75dB DCC daily 10 hour limit were recorded on the following dates: 1st October 2019, the noise report states the cause of this breach was “*ambient traffic noise*”. The value of the exceedance is 76.4 dB LA_{eq10hr}.